

Orlando Weather Comparison

February 2012

Date	<u>Current Year - 2012</u>					<u>Last Year - 2011</u>				
	Temperatures			Degree-Days		Temperatures			Degree-Days	
	High	Low	Rainfall	Heating HDD	Cooling CDD	High	Low	Rainfall	Heating HDD	Cooling CDD
<i>01-Feb</i>	80	53	0.00	0	2	82	56	0.00	0	4
<i>02-Feb</i>	82	55	0.00	0	4	81	65	0.00	0	8
<i>03-Feb</i>	75	60	0.00	0	3	77	61	0.00	0	4
<i>04-Feb</i>	80	62	0.00	0	6	83	61	0.00	0	7
<i>05-Feb</i>	83	59	0.00	0	6	82	59	0.01	0	6
<i>06-Feb</i>	81	64	0.68	0	8	64	57	0.07	4	0
<i>07-Feb</i>	70	61	0.00	0	1	85	57	0.10	0	6
<i>08-Feb</i>	79	57	0.00	0	3	59	45	0.00	13	0
<i>09-Feb</i>	74	55	0.00	0	0	76	43	0.00	5	0
<i>10-Feb</i>	81	58	0.30	0	5	69	52	0.07	4	0
<i>11-Feb</i>	69	48	0.00	6	0	60	49	0.00	10	0
<i>12-Feb</i>	53	32	0.00	22	0	64	41	0.00	12	0
<i>13-Feb</i>	67	33	0.00	15	0	68	37	0.00	12	0
<i>14-Feb</i>	78	45	0.00	3	0	72	42	0.00	8	0
<i>15-Feb</i>	82	53	0.00	0	3	76	49	0.00	2	0
<i>16-Feb</i>	83	62	0.00	0	8	77	52	0.00	0	0
<i>17-Feb</i>	78	61	0.01	0	5	80	53	0.00	0	2
<i>18-Feb</i>	78	64	0.00	0	6	84	57	0.00	0	6
<i>19-Feb</i>	86	63	0.00	0	10	83	56	0.00	0	5
<i>20-Feb</i>	70	53	0.00	3	0	81	53	0.00	0	2
<i>21-Feb</i>	77	49	0.00	2	0	85	55	0.00	0	5
<i>22-Feb</i>	79	59	0.88	0	4	85	59	0.00	0	7
<i>23-Feb</i>	86	64	0.00	0	10	83	61	0.00	0	7
<i>24-Feb</i>	89	65	0.00	0	12	82	58	0.00	0	5
<i>25-Feb</i>	71	55	0.00	2	0	86	63	0.00	0	10
<i>26-Feb</i>	69	55	0.00	3	0	86	59	0.00	0	8
<i>27-Feb</i>	86	64	1.27	0	10	85	58	0.00	0	7
<i>28-Feb</i>	80	63	0.00	0	7	88	62	0.00	0	10
<i>29-Feb</i>	85	63	0.00	0	9	80	60	0.11	0	5
Average	77.6	56.4				78.0	54.5			
Total			3.14	56	122			0.36	70	114
Normal	72.7	49.7	2.08	111	62	72.7	49.7	2.08	111	62
Departure	4.9	6.7	1.06	-55	60	5.3	4.8	-1.72	-41	52
Number of Days	29									

Rainfall and temperature readings are recorded by the National Weather Service (NWS) at Orlando International Airport (MCO).

Normal is an average over the 1995-2009 period. Departure is an amount above or below normal. A DEGREE-DAY is the difference between a particular day's mean (average of maximum and minimum) temperature and a base temperature of 65 deg. F.

One COOLING DEGREE-DAY (CDD) is counted for each degree higher than this base, and one HEATING DEGREE-DAY (HDD) is counted for each degree lower. Normal weather values reflect the entire month.

01-Mar-12